



Government Of West Bengal
Office Of The Divisional Fire Officer, Bankura
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Memo no.: FSR/0125186237800171

Date: 29-08-2023

From:
Divisional Fire Officer, Bankura
West Bengal Fire & Emergency Services

To: Athena B.Ed. College,
Vill and Mouza - Churamonipur, Plot no. 55, Kh no. 316, J.I no. 77, under Kochdihi G. P, P.O and P.S. Sonamukhi,
Dist. Bankura, Pin - 722207.

Sub: Issuance of Fire Safety Certificate for an existing construction of G+I storied Educational in the name and style as "Athena B.Ed college" at the premises of-Mouza-churamonipur, plot no.55, kh no.316, j I no.77, under Kochdihi G.P, po,ps.sonamukhi, Bankura, pin-722207.

This is in reference to your application no. 0125189237800050 dated 14-08-2023 regarding the Issuance of Fire Safety Certificate for an existing construction of G+I storied Educational in the name and style as "Athena B.Ed college" at the premises of-Mouza-churamonipur, plot no.55, kh no.316, j I no.77, under Kochdihi G.P, po,ps.sonamukhi, Bankura, pin-722207.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

-The performance of the firefighting system as incorporated into the building was tested at random and found satisfactory working conditions. Given the above, this office is releasing the Fire Safety Recommendation for occupancy of the aforesaid building. However, to up-keep the fire safety measure of the aforesaid building the following safety measures need to be incorporated /maintained.

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the driveway.
2. To eliminate the risk of fire hazards, good housekeeping both inside and outside of the building shall be strictly maintained.
3. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceilings.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.
5. The notice of firefighting and evacuation plan from the building shall be prepared and displayed at all suitable places in

the building.

6. The employees and security staff shall be conversant with the installed firefighting equipment of the building and to operate in the event of fire and testing.

7. Mock fire practice and evacuation drills shall be performed periodically with the participation of all occupants of the building.

8. Transformer and switchgear room shall be protected with an automatic CO2 or DCP fire extinguisher conforming to I.S. specifications.

9. A crew of trained firemen under the experienced officer shall be maintained around the clock for the safety of the building.

10. Arrangements shall be made for regular checking, testing, and proper maintenance of all the fire safety installation and equipment installed in the building to keep them in perfectly good Working conditions at all times.

11. The fire safety audit is to be conducted a regular intervals and to be recorded in the fire prevention maintenance register.

12. Fire notice for firefighting and evacuation from the building shall be prepared and displayed at all vulnerable places of the building.

13. Floor numbers and directional signs of the escape route shall be displayed prominently.

Any deviation and changes like the use of the building in respect of the submitted of plan drawing, without obtaining prior permission from the office, the FSC shall be treated cancelled.

14. This Fire Safety Certificate has a validity of 03 years and have to be renewed on ea

Divisional Fire Officer, Bankura
West Bengal Fire & Emergency Services

Memo No.: FSR/012518623780050